

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED OUTDOOR LIGHT

Name and address of the applicant

Ningbo Kangyan Lighting Electric Co. Ltd
Houyu Industry Area, Liangnong, 315430 Yuyao, Zhejiang, China

Name and address of the manufacturer

Ningbo Kangyan Lighting Electric Co. Ltd
Houyu Industry Area, Liangnong, 315430 Yuyao, Zhejiang, China

Name and address of the factory


Ningbo Kangyan Lighting Electric Co. Ltd
Houyu Industry Area, Liangnong, 315430 Yuyao, Zhejiang, China*When more than one factory*☐ Additional information on page 2

Ratings and principal characteristics

Product data

Ratings: 200 -240 V~; 50/60 Hz; max 400 W; IP 66; class I; ta: 55 °C (For BELL series) / ta: 50 °C (For other series)

Trademark / Brand (if any)

KANGLIGHT or LUXiFiC
KANGLIGHT or LUXIFIC

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

ACORNIA series, BELL series, LUXERA series and VEGA series

Additional information

☒ Additional information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-2-3:2002, IEC 60598-2-3:2002/AMD1:2011 and IEC 60598-1:2020

National differences:

EU Group Differences, EU Special National Conditions

As shown in the Test Report Ref. No. which forms part of this Certificate

6251245.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-01-06

Signature: Cliff Lin

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional information

For detailed explanation for model names, please see appendix 1

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
6825 MJ Arnhem
Netherlands

Date: 2026-01-06

A handwritten signature in blue ink, appearing to read 'Cliff Lin'.

Signature: Cliff Lin

