ATTESTATION OF CONFORMITY

Issued to:	Ningbo Kangyan Lighting Electric Co., Ltd. Houyu Industry Area, Liangnong, 315430, Yuyao, Zhejiang, China
For the product:	LED Outdoor Light
Trade name:	KANGLIGHT, LUXiFiC
Type/Model:	SPM series; SPS series; see annex model list for more information.
Ratings:	220-240V~, 50/60Hz, Class I, IP66, see annex model list for more information.
Manufactured by:	Ningbo Kangyan Lighting Electric Co., Ltd. Houyu Industry Area, Liangnong, 315430, Yuyao, Zhejiang, China
Subject:	Complete evaluation of electrical system of the appliances
Requirements:	Clause 9.2.2, 9.2.7 of EN IEC 60598-1:2021+A11:2022 and EN 60598-2-3:2003+A1:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test file / test report no 6218976.50QS.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Arnhem, 22 October 2025 Number: 6218976.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kate Xu
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing and Certification (Shanghai) Ltd.
5F #250 Jiangchangsan Road Shibei Hi-Tech Park, 200436 Jing'an District, Shanghai, China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-product-safety.com

Annex

Certificate Number: 6218976.01AOC

Model list:

Model	Rated power (W)	ta (°C)
SPS series	8 - 110	45 for 8 - 110 W 50 for 8 - 100 W 55 for 8 - 80 W
SPM series	15 - 150	45 for 15 - 150 W 50 for 15 -140 W 55 for 15 - 130 W